

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: May 12, 2026
 Sample ID: 260426015
 Date Analyzed: 5/6/26
 WO Number: 260428033

RECEIVED

MAY 12 2026

Fort Plain Central School
 Superintendent's Office

Customer: Ft. Plain School District
Address: 25 High Street, Ft. Plain, New York 13339
Sample Location: Ft. Plain Elementary School and High School
Sample Point: See Chart
Water Source: Municipal Water
Chlorinated: Yes

Collection Date: 4/26/26
Collection Time: See Chart
Collected by: Angelo Finateri
Potable: Yes
Grab/Composite: Grab
Receipt Temp: Ambient

Sample #	Ft. Plain Elementary School Sample Point	Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifier	Method
23	Sink Kitchen middle	9:14 AM	4/26/26	2.1	5.0		EPA 200.8 REV 5.4
15	Sink Kitchen by convection oven	9:15 AM	4/26/26	3.9	5.0		EPA 200.8 REV 5.4
12	Sink Kitchen island	9:21 AM	4/26/26	3.4	5.0		EPA 200.8 REV 5.4
7	Outlet Kitchen filler for steam kettle	9:16 AM	4/26/26	1.8	5.0		EPA 200.8 REV 5.4
20	Fountain Athletic hallway by cafeteria	9:48 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4
47	Sink #15 snack shack	9:22 AM	4/26/26	3.3	5.0		EPA 200.8 REV 5.4
24	Sink #10 counter work room	9:25 AM	4/26/26	5.4	5.0		EPA 200.8 REV 5.4
13	Sink room #59 counter conference	9:27 AM	4/26/26	3.5	5.0		EPA 200.8 REV 5.4
39	Sink #57 counter	9:29 AM	4/26/26	3.5	5.0		EPA 200.8 REV 5.4
51	Sink #57 exam room	9:30 AM	4/26/26	3.6	5.0		EPA 200.8 REV 5.4
49	Fountain Hallway by #57	9:31 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4
6	Sink #45 workroom counter	9:41 AM	4/26/26	8.4	5.0	X	EPA 200.8 REV 5.4
****	Sink #46 workroom counter - No sink / Not Tested	****	****	****	5.0		EPA 200.8 REV 5.4
33	Fountain Hallway by #25	9:47 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4
38	Fountain Hallway by #68	9:34 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4
28	Sink #68 women's RR	9:35 AM	4/26/26	7.8	5.0	X	EPA 200.8 REV 5.4
36	Sink #63 counter	9:37 AM	4/26/26	3.1	5.0		EPA 200.8 REV 5.4
50	Tap Sports Complex by light pole	9:55 AM	4/26/26	2.3	5.0		EPA 200.8 REV 5.4
1	Snack Shack Ice machine	9:23 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4
26	Kitchen Sink by Exterior door	9:50 AM	4/26/26	5.0	5.0		EPA 200.8 REV 5.4
41	Bottle Fill - Athletic Hallway	9:49 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4
18	Bottle Fill by Room 57	9:32 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4
21	Bottle fill by Room 68	9:34 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: May 12, 2026
 Sample ID: 260426015
 Date Analyzed: 5/6/26
 WO Number: 260428033

Customer: Ft. Plain School District
 Address: 25 High Street, Ft. Plain, New York 13339
 Sample Location: Ft. Plain Elementary School and High School
 Sample Point: See Chart
 Water Source: Municipal Water
 Chlorinated: Yes

Collection Date: 4/26/26
 Collection Time: See Chart
 Collected by: Angelo Finateri
 Potable: Yes
 Grab/Composite: Grab
 Receipt Temp: Ambient

Sample #	Ft. Plain High School Sample Point			Collection Time	Date	Test Result (µg/l)	MCL (µg/l)	Qualifier	Method
35	Sink	#113	counter right	8:20 AM	4/26/26	3.1	5.0		EPA 200.8 REV 5.4
22	Sink	#113	counter left	8:25 AM	4/26/26	1.1	5.0		EPA 200.8 REV 5.4
55	Fountain	Hallway by pay phones		8:27 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4
46	Fountain	Gym Hallway by girls PE office		8:28 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4
54	Sink	Work room		8:30 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4
45	Ice Machine	Kitchen		8:34 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4
30	Sink	Kitchen	left of ice machine	8:33 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4
8	outlet	Kitchen	Kettle	8:37 AM	4/26/26	6.2	5.0	X	EPA 200.8 REV 5.4
48	Outlet	Kitchen	steam table	8:38 AM	4/26/26	1.7	5.0		EPA 200.8 REV 5.4
9	Sink	Nurse	counter	8:41 AM	4/26/26	1.1	5.0		EPA 200.8 REV 5.4
11	Sink	Faculty	counter	8:43 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4
29	Fountain	1st Floor	by boys basement	8:45 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4
32	Sink	#002	counter right of door	8:47 AM	4/26/26	1.1	5.0		EPA 200.8 REV 5.4
25	Sink	#001	counter left of door	8:48 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4
3	Sink	#201	2nd straight in counter	8:55 AM	4/26/26	2.9	5.0		EPA 200.8 REV 5.4
34	Fountain	2nd Floor	by faculty rr	8:54 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4
17	Sink	#208	1st left of door	8:50 AM	4/26/26	1.5	5.0		EPA 200.8 REV 5.4
19	Sink	#208	2nd left of door	8:51 AM	4/26/26	1.6	5.0		EPA 200.8 REV 5.4
10	Sink	#208	3rd left of door	8:52 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4
14	Sink	#303	far left corner	9:02 AM	4/26/26	8.2	5.0	X	EPA 200.8 REV 5.4
16	Sink	#304	far right corner	9:04 AM	4/26/26	3.4	5.0		EPA 200.8 REV 5.4
42	Fountain	3rd Floor	by faculty rr	8:59 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4
4	Bottle fill by gym			8:28 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4
31	Bottle fill	2nd floor by rest rooms		8:54 AM	4/26/26	ND	5.0		EPA 200.8 REV 5.4

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: May 12, 2026
 Sample ID: 260426015
 Date Analyzed: 5/6/26
 W/O Number: 260428033

Customer:	Ft. Plain School District	Collection Date:	4/26/26
Address:	25 High Street, Ft. Plain, New York 13339	Collection Time:	See Chart
Sample Location:	Ft. Plain Elementary School and High School	Collected by:	Angelo Finateri
Sample Point:	See Chart	Potable:	Yes
Water Source:	Municipal Water	Grab/Composite:	Grab
Chlorinated:	Yes	Receipt Temp:	Ambient

*MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards. Please see comments below.

Comments:

All test results are not within acceptable limits, please consult chart. If you have any questions, please call the laboratory.

*Revisions to Public Health Law (Section 1110) which governs school potable water testing and standards were finalized on March 4, 2022. The revised law took effect on December 22, 2022. The key revisions to the law which will require changes to Subpart 67-4 include:

1. The revised action level of lead in drinking water is 5 parts per billion (ppb, µg/l), reduced from 15 ppb (µg/l).
2. School buildings deemed "lead-free" are no longer exempt from testing requirements per Subpart 67-4.

Qualifiers:	C+: CCV above acceptable limits
ND: Not Detected at the reporting limit	S: LCS Spike recovery is below acceptable Limits
J: Analyte detected below quantitation limit	S+: LCS Spike recovery is above acceptable Limits
B: Analyte detected in Blank	Z: Duplication outside acceptable limits
X: Exceeds maximum contamination limit	T: Tentatively Identified Compound – Estimated
H: Hold time exceeded	E Above quantitation range - Estimated
N: Matrix Spike below acceptable limits	
N+: Matrix Spike above acceptable limits	
S: LCS Spike recovery outside acceptable limits	
C: CCV below acceptable limits	

Legend:
 < = Less than
 > = Greater than
 ≈ = Approximately
 ND = Not Detected at reporting limit
 NP = Not Provided
 mg/l = milligrams per liter = ppm
 ppm = parts per million
 µg/l = micrograms per liter = ppb
 ppb = parts per billion
 gpg = grains per gallon
 MCL = Maximum Contaminant Level
 SM = Standard Methods For the Examination of Water and Wastewater

Reviewed by Angelo E. Finateri Angelo E. Finateri
 Environmental Laboratory NYSDOH E.L.A.P. #10709